




# Cast Aluminum Street Light Control Cabinet

From: **ALLOY CASTINGS CO., INC.**  
*Quality Aluminum Castings Since 1948*



151 West Union Street • P.O. Box 473 • East Bridgewater, MA 02333-0473  
 Telephone: (508) 378-2541 • FAX: (508) 378-1240  
 www.alloycastings.com

### Notes:

1. Raised (0.025") Letters Cast Integral with Door.
2. Cabinet Wall Thickness: 3/16" min. - 5/16" max.
3. MATERIAL: Alloy composition A356-2  
 FINISH: One coat of metal primer, sanded smooth after dry and painted to your specifications.
4. Cabinet construction is in accordance with requirements of N.E.M.A. AND A.S.T.M. wherever such standards and tests apply.
5. Recommended anchorage: Four (4) 3/4" D x 24" L x 3" hook hot dipped galvanized anchor bolts (by others). Bolt Projection above concrete foundation 4" min - 5" max.



**ACCC-10**



Door is 24-3/4 x 37-3/4 with weatherproof Neoprene gasketing cemented in recessed groove in body

\*Bolt hole layout for 4-3/4" Anchor Bolts

Cabinet Wall thickness 3/16" Min.